

Inlet & Outlet Online Monitoring Data

Sr. No.	Date	INLET					OUTLET				
		pH	BOD (mg/l)	COD (mg/l)	TSS (mg/l)	TDS (mg/l)	pH	BOD (mg/l)	COD (mg/l)	TSS (mg/l)	TDS (mg/l)
1	25/03/2019	8.28	142	520	129	2874	5.25	26.9	112	28	1405
2	18/03/2019	7.57	84	284	69	2386	6.72	12	72	20	1398
3	11/03/2019	7.43	225	868	79	2689	5.99	26.4	120	40	1296
4	05/03/2019	7.63	178	688	94	2228	7.9	14.8	80	20	690
5	26/02/2019	7.95	210	760	154	1964	6.41	15.2	88	20	857
6	18/02/2019	7.94	160	628	108	4020	6.8	26	88	26	557
	Average	7.8	166.5	624.67	105.5	2693.5	6.51	20.22	93.33	25.67	1033.83